

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7165-0554:116 Page 1 of 1

**CATEGORY:** Control Units (Non High-Rise)

**LISTEE:** Johnson Controls Inc., 507 E. Michigan St, Milwaukee, WI 53202-5211  
Contact: James D. Kinney (414) 524-4358 Fax (414) 276-5979

**DESIGN:** Model IFC-200 fire alarm control unit. Local, auxiliary, remote station (PPU), proprietary (PPU) and central station (PPU). Also suitable for releasing device service. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

4XTM	Transmitter Module
RTM-8	Relay Module
DP-AFP200/*ADP-4	Dress Panel
TR-4XG	Trim Ring
MMX-1, -101	Monitor Module
ISO-X	Loop Isolator Module
N-ELR	EOL Resistors
CRT-2	Terminal with Keyboard
VS4095/5	Printer
CMX-1	Control Module
BB-17	Battery Box
AVPS-24	Power Supply
*MPD-24A/-24B	Main Power Supply
NAM-232	Network Adapter Module
*INA	Intelligent Network Annunciator
*CAB Series	Enclosure
*ABS-4D, ABF-4	INA Cabinet
4XMM	Meter Module
*MIB-W, -F, -WF	Media Interface Board

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices. Suitable for central station (PPU) service when used with separately listed compatible DACT.

This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**XLF:** 7165-0028:164

\*Rev. 2-04-2003KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 4, 2003**

*Listing Expires June 30, 2003*

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**